# Sensor readings, 21 to 27 October

Sensor A, logged every 10 minutes. Daily minimum and maximum air temperature, mean relative humidity and hours with the roof vents open.

| Day | Min °C | Max °C | Humidity % | Vents open (h) |
|---|---|---|---|---|
| Tue 21 Oct | 14.8 | 26.1 | 71 | 5.5 |
| Wed 22 Oct | 15.2 | 27.4 | 68 | 6.0 |
| Thu 23 Oct | 13.9 | 24.8 | 74 | 3.5 |
| Fri 24 Oct | 16.1 | 28.3 | 66 | 7.0 |
| Sat 25 Oct | 15.7 | 25.9 | 70 | 5.0 |
| Sun 26 Oct | 14.2 | 23.6 | 77 | 2.5 |
| Mon 27 Oct | 15.0 | 26.7 | 69 | 5.5 |

The house went over the 27 °C limit on two days, Wednesday and Friday. On both days the vents opened later than the controller schedule says.

